

OFTEC TECHNICAL BOOK THREE

REGIONAL REQUIREMENTS

Minimum Provision for New Systems in New and Existing Dwellings

For oil fired boilers installed on or after April 2007:

- All oil fired boilers shall have SEDBUK efficiency of not less than 86% and be of the condensing type.

For range cooker boilers (as per the Department of Communities and Local Government for England and Wales, Domestic Heating Compliance Guide):

- All oil fired range cooker boilers should have an efficiency greater than 75%*

* As declared on www.rangeefficiency.org.uk

Appliance minimum SEDBUK efficiencies on new build properties form part of the SAP calculation process, it is therefore important that the appliance efficiency utilised (as specified by the builder, developer, architect or consultant) is matched to this requirement. No variation to this should take place without prior consultation and agreement of the specifier.

Systems for space and domestic hot water are required to have:

- Primary circuits of the fully pumped type with full boiler controls, interlock and zones.
- An automatic bypass valve as required by the appliance manufacturer's installation instructions.
- Vented hot water cylinders complying with the heat loss and heat exchanger requirements of BS 1566.
- Un-vented hot water storage systems complying with BS 7206 or be certified by the British Board of Agrément or equivalent approval.
- Been thoroughly cleaned and flushed using an appropriate inhibitor.
- Water treatment provided in hard water areas.
- All appliances, systems and associated equipment fully commissioned in accordance with manufacturer's instructions.

Minimum Provision for Replacement Systems in Existing Dwellings

For oil fired boiler replacements not involving a fuel or energy switch:

- As defined above
- The SEDBUK efficiency should not be worse than 2 percent lower than the SEDBUK efficiency of the appliance being replaced.

NOTE: If the efficiency of the system or appliance is not known, efficiency values can be taken from table 4a or 4b of SAP 2005.